

**ADDENDUM# 1**  
**UNDERGROUND OIL TANK REMOVAL**  
**Bid # 6204F**

**May 26, 2011**

**Dear Vendors:**

**The Contract Bidding Documents pursuant to Bid # 6204F are hereby revised as follows:**

**The following are in response to questions received:**

- Q1: Does oil have to be transferred to another site?  
**A1: *No, there will be a small amount of residual that will need to be removed as stated in the scope.***
- Q2: How much oil in each tank?  
**A2: *We anticipate less than 200 gallons.***
- Q3: Is soil testing by contractor?  
**A3: *Yes, unless we hit contamination. A third party environmental company will over see the project from that point.***
- Q4: Are all tanks steel?  
**A4: *Yes***
- Q5: Are hold down pads to be removed if any?  
**A5: *We do not believe there are any pads but if so they may stay if there is no contamination.***
- Q6: Is asphalt 1 or 2 courses.  
**A6: *One (1) coarse***

Thank you for your patience, time and consideration.

Sincerely,



Tammy Bradley, CPM, C.P.P.B.  
Sr. Buyer

---

C: Mike Longo, Facilities Manager  
TOWN OF WEST HARTFORD, CT 06107-2431  
(860) 561-7470 FAX: 561-7492



Printed on Recycled Paper